

WPC response to the following planning application:

**DC/21/3939/FUL Riffams Cliff Road Waldringfield IP12 4 QL** Single Storey rear extension and attached carport. Case officer Nick Clow. Comments by 21st September 2021.

Waldringfield Parish Council has no objection to this application.

However we notice on the construction notes under “Electrics” states that *“Fixed external lighting to be controlled via sensors which automatically turn off lights when not required and when there is sufficient daylight”*.

The village of Waldringfield is, in the main, a “dark skies” area. We would therefore ask the applicants to support this by ensuring that any external lighting is controlled by sensors that respond to movement rather than the level of light, thereby avoiding external lighting for the entire dusk to dawn period.